

Confirmation

LEED

On 30/05/2017, Eurofins Product Testing A/S received a sample of compact laminated panel with the product name:

PRINT HPL STR.

supplied by

Abet Laminati S.p.A

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000 and CDPH testing standards (See test report no. 392-2017-00192301_H_EN_Rev1).

The test results of the tested product indicate that the product qualifies for LEED v4 specifications on VOC emissions by complying with:


VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of CDPH-IAQ (California Department of Public Health, Jan 2017); and a TVOC below 0.5 mg/m³ in both office and class room.

25 July 2017



Maria Pelle Madsen
Analytical Chemist



Thomas Bjerring
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.